

Facility Summary in BLAINE County in the City of CHINOOK

Location: EZZIES WHOLESALE INC CHINOOK
40450 US HIGHWAY 2 E
CHINOOK, MT 59523 BLAINE

Sys Fac ID: 03-07801

Last Inspected On: 6/29/2015

Operating Permit Renewal Date: 10/30/2018

Contact: Dave Skiff, (406) 654-2331

Owners/Operators: EZZIES WHOLESALE INC, Owner (406)-654-2331 PO BOX 1770
MALTA MT 59538-9640

David Skiff, UST Class A Operator
TRISHA HUESTIS, UST Class B Operator
Sherry Ortner, UST Class B Operator
Shannon Partridge, UST Class B Operator
David Skiff, UST Class B Operator
Durwin Williams, UST Class B Operator
David Skiff, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
6	03	5/1/2012	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve, High Level Alarm
5332			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes
7	03	5/1/2012	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve, High Level Alarm
5333			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
5,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes
8	03	5/1/2012	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve, High Level Alarm
5334			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
10,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes

Facility Summary in BLAINE County in the City of CHINOOK

Location: EZZIES WHOLESALE INC CHINOOK
40450 US HIGHWAY 2 E
CHINOOK, MT 59523 BLAINE
Contact: Dave Skiff, (406) 654-2331

Sys Fac ID: 03-07801
Last Inspected On: 6/29/2015
Operating Permit Renewal Date: 10/30/2018

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
9	03	5/1/2012	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve, High Level Alarm
5335			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
5,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes
10	03	5/1/2012	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve, High Level Alarm
5336			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes
11	03	5/1/2012	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve, High Level Alarm
5337			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	Automatic Tank Gauging 0.2, ELLD Line Tightness Testing	
15,000			TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	Yes

Facility Summary in BLAINE County in the City of CHINOOK

Location: TOWN PUMP INC CHINOOK FOOD STORE
108 NEW YORK ST
CHINOOK, MT 59523 BLAINE

Sys Fac ID: 03-08688

Last Inspected On: 12/28/2015

Operating Permit Renewal Date: 4/1/2019

Contact: Trent Biggers, (406) 497-6700

Owners/Operators: Town Pump of Chinook Inc, Owner (406)-497-6700 PO BOX 6000
BUTTE MT 59702-6000

Charles A Armstrong, UST Class A Operator
Trent Biggers, UST Class A Operator
Don Edmisten, UST Class A Operator
Daniel Sampson, UST Class A Operator
Charles A Armstrong, UST Class B Global Operator
Trent Biggers, UST Class B Global Operator
Don Edmisten, UST Class B Global Operator
Daniel Sampson, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	23	1/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2384			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		11/28/2012	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000		11/3/2006	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
2	23	1/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2385			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Gasoline		11/28/2012	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000		11/3/2006	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
3	23	1/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
4462			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		11/28/2012	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000		11/3/2006	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in BLAINE County in the City of CHINOOK

Location: TOWN PUMP INC CHINOOK FOOD STORE
108 NEW YORK ST
CHINOOK, MT 59523 BLAINE

Sys Fac ID: 03-08688

Last Inspected On: 12/28/2015

Operating Permit Renewal Date: 4/1/2019

Contact: Trent Biggers, (406) 497-6700

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	23	1/1/1993	Fiberglass Reinforced Plastic	Fiberglass Reinforced Plastic	Ball Float Valve
2382			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel		11/28/2012	Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
12,000		11/3/2006	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
10	14	6/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4354			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
10,000		11/5/2006	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	
11	14	6/1/2001	Fiberglass Reinforced Plastic	Flexible Plastic	Ball Float Valve
4355			Double-Walled	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Not Applicable
Diesel			Continuous Interstitial Monitor, Stat. Inventory Reconciliation, Approved Remote Monitoring	Stat. Inventory Reconciliation, Approved Remote Monitoring	
5,000		11/5/2006	TLS-350/Gilbarco EMC , Veeder Root	Continuous Interstitial Monitor	

Facility Summary in BLAINE County in the City of CHINOOK

Location: MILK RIVER COOP
135 1ST ST
CHINOOK, MT 59523 BLAINE

Sys Fac ID: 03-10274

Last Inspected On: 12/18/2012

Operating Permit Renewal Date: 5/7/2016

Contact: Daniel Johnson, (406) 357-2280

Owners/Operators: CHS Inc - Inver Grove Heights, Owner (800)-232-3639 5500 CENEX DR
INVER GROVE HEIGHTS MN 55077-1721
Milk River Cooperative, Operator (406)-357-2280 PO BOX 339
CHINOOK MT 59523-0339
Steve Kleinjan, UST Class A Operator
Brenda Drugge, UST Class B Operator
Steve Kleinjan, UST Class B Operator
Logan Abrahamson, UST Class B Global Operator
Willard Abrahamson, UST Class B Global Operator
Steve Kleinjan, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	20	4/1/1995	Steel Clad	Flexible Plastic	Ball Float Valve
962		6/7/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Gasoline		12/18/2012	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
10,000					
2	20	4/1/1995	Steel Clad	Flexible Plastic	Ball Float Valve
963		6/7/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Gasoline		12/18/2012	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
10,000					
3	20	4/1/1995	Steel Clad	Flexible Plastic	Ball Float Valve
964		6/7/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Gasoline		12/18/2012	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
20,000					

Facility Summary in BLAINE County in the City of CHINOOK

Location: MILK RIVER COOP
135 1ST ST
CHINOOK, MT 59523 BLAINE

Sys Fac ID: 03-10274

Last Inspected On: 12/18/2012

Operating Permit Renewal Date: 5/7/2016

Contact: Daniel Johnson, (406) 357-2280

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	20	4/1/1995	Steel Clad	Flexible Plastic	Ball Float Valve
965		6/7/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Diesel		12/18/2012	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000					
5	20	4/1/1995	Steel Clad	Flexible Plastic	Ball Float Valve
966		6/7/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Diesel		12/18/2012	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000					
6	20	4/1/1995	Steel Clad	Flexible Plastic	Ball Float Valve
967		6/7/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Diesel		12/18/2012	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000					
17	20	4/1/1995	Steel Clad	Flexible Plastic	Ball Float Valve
968		6/7/2013	Double-Walled	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Galvanic
Diesel		12/18/2012	Automatic Tank Gauging 0.2	Continuous Interstitial Monitor	
12,000					

Facility Summary in BLAINE County in the City of HARLEM

Location: E Z MART
US HIGHWAY 2
HARLEM, MT 59526 BLAINE
Contact: Doug McCracken, (406) 353-2411

Sys Fac ID: 03-05982
Last Inspected On: 6/20/2013
Operating Permit Renewal Date: 7/9/2016

Owners/Operators: E Z Mart, Owner (406)-353-2335 PO BOX 249
HARLEM MT 59526-0249
Douglas McCracken, UST Class A Operator
Deb Newman, UST Class A Operator
Douglas McCracken, UST Class B Operator
Deb Newman, UST Class B Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	22	8/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3265			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		3/19/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, MLLD Line Tightness Testing	
12,000		7/10/2009			
5	22	8/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3266			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		3/19/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, MLLD Line Tightness Testing	
12,000		7/10/2009			
6	22	8/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3267			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		3/19/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor	
12,000		7/10/2009			

Facility Summary in BLAINE County in the City of HARLEM

Location: E Z MART
US HIGHWAY 2
HARLEM, MT 59526 BLAINE
Contact: Doug McCracken, (406) 353-2411

Sys Fac ID: 03-05982
Last Inspected On: 6/20/2013
Operating Permit Renewal Date: 7/9/2016

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
7	22	8/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3268			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		3/19/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, MLLD Line Tightness Testing	
12,000		7/10/2009			
8	22	8/1/1993	Cathodically Protected Steel	Fiberglass Reinforced Plastic	High Level Alarm
3269			None	Double-Walled	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		3/19/2013	Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2, Continuous Interstitial Monitor, MLLD Line Tightness Testing	
12,000		7/10/2009			

Facility Summary in BLAINE County in the City of HARLEM

Location: FORT BELKNAP KWIKSTOP
148 ASSINBOINE AVE
HARLEM, MT 59526 BLAINE

Sys Fac ID: 03-09729

Last Inspected On: 11/25/2014

Operating Permit Renewal Date: 3/10/2018

Contact: Dave Skiff, (406) 654-2331

Owners/Operators: Fort Belknap Indian Community, Owner

(406)-353-2205

656 AGENCY MAIN STREET
HARLEM MT 59526-9705

Kwikland LLP, Operator

(406)-353-4964

PO BOX 729
HARLEM MT 59526

David Skiff, UST Class A Operator

Valerie Blackcrow, UST Class B Operator

Raymond D Gone, UST Class B Operator

David Skiff, UST Class B Operator

David Skiff, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	27	8/2/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3820			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/25/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
10,000		11/9/2011			
2	27	8/2/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3821			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/25/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
10,000		11/9/2011			
3	27	8/2/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3822			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Gasoline		11/25/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
6,000		11/9/2011			

Facility Summary in BLAINE County in the City of HARLEM

Location: FORT BELKNAP KWIKSTOP
148 ASSINBOINE AVE
HARLEM, MT 59526 BLAINE

Sys Fac ID: 03-09729

Last Inspected On: 11/25/2014

Operating Permit Renewal Date: 3/10/2018

Contact: Dave Skiff, (406) 654-2331

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	27	8/2/1988	Cathodically Protected Steel	Fiberglass Reinforced Plastic	Flapper Valve (Auto Shutoff)
3823			None	None	Yes
Currently in Use			Electronic Line Leak Detector	Pressurized	Galvanic
Diesel		11/25/2014	Automatic Tank Gauging 0.1, Automatic Tank Gauging 0.2	Automatic Tank Gauging 0.2, MLLD Line Tightness Testing	
10,000		11/9/2011			

Facility Summary in BLAINE County in the City of TURNER

Location: FARMERS UNION OIL CO TURNER
US HIGHWAY 241
TURNER, MT 59542 BLAINE

Sys Fac ID: 56-13805

Last Inspected On: 4/4/2014

Operating Permit Renewal Date: 6/21/2017

Contact: Chet Fouts, (406) 357-2280

Owners/Operators: Farmers Union Oil Co Chinook, Owner (406)-357-2280 PO BOX 339
CHINOOK MT 59523-0339

Johannas Brown, UST Class A Operator
Steve Kleinjan, UST Class A Operator
Johannas Brown, UST Class B Operator
Steve Kleinjan, UST Class B Operator
Logan Abrahamson, UST Class B Global Operator
Willard Abrahamson, UST Class B Global Operator
Steve Kleinjan, UST Class B Global Operator

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
1	18	8/14/1997	Unknown	Flexible Plastic	
969	Yes	5/9/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Not Listed	Continuous Interstitial Monitor	
10,000					
2	18	8/14/1997	Unknown	Flexible Plastic	
970	Yes	5/9/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Not Listed	Continuous Interstitial Monitor	
10,000					
3	18	8/14/1997	Unknown	Flexible Plastic	
971	Yes	5/9/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Gasoline			Not Listed	Continuous Interstitial Monitor	
10,000					

Facility Summary in BLAINE County in the City of TURNER

Location: FARMERS UNION OIL CO TURNER
US HIGHWAY 241
TURNER, MT 59542 BLAINE
Contact: Chet Fouts, (406) 357-2280

Sys Fac ID: 56-13805
Last Inspected On: 4/4/2014
Operating Permit Renewal Date: 6/21/2017

Tank Id	Age	Installed	Tank Material of Construction	Piping Material	Overfill Types
Tag Number	AST	Sump Tightness	Secondary Option	Secondary Option	Spill Protected
Status		Inventory Control	Catastrophic L.D. Type 3.0	Piping Type	CP Met Types
Product		Tank/Pipe CP	Tank Detection	Primary Pipe Detection	Vapor Recovery
Capacity		Line Tightness	ATG Type	Secondary Pipe Detection	Energy Act
4	18	8/14/1997	Unknown	Flexible Plastic	
972	Yes	5/9/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Not Listed	Continuous Interstitial Monitor	
6,000					
5	18	8/14/1997	Unknown	Flexible Plastic	
3606	Yes	5/9/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Not Listed	Continuous Interstitial Monitor	
6,000					
6	18	8/14/1997	Unknown	Flexible Plastic	
3607	Yes	5/9/2013	None	Double-Walled	Yes
Currently in Use			Continuous Interstitial Monitoring	Pressurized	Not Applicable
Diesel			Not Listed	Continuous Interstitial Monitor	
6,000					